

CAMPBELL COUNTY

EXECUTIVE DIRECTOR
JEFFREY S. WELLS, P.E.
jwells@ccusa-water.com



TELEPHONE
(434) 239-8654

FAX
(434) 237-5820

OPERATIONS SUPERINTENDENT
JOSHUA S. PRIBBLE
jspribble@ccusa-water.com

UTILITIES AND SERVICE AUTHORITY

THIS IS A SEALED BID REQUEST **NOT A PURCHASE ORDER**

DATE: August 19, 2024

SEALED BIDS, for the herein-specified Fire Hydrant Maintenance and Painting will be received at Campbell County Utilities and Service Authority, 20644 Timberlake Road, Lynchburg, Virginia 24502, office until:

August 27, 2024, 2:30 P.M. (EST)

At which time the bids will be publicly opened and read aloud.

All Bids shall be subject to the conditions and instructions as follows:

INSTRUCTIONS

- 1. The Bid shall be placed in a sealed envelope bearing the bidder's name and address and clearly marked "Fire Hydrant Maintenance and Painting" ON August 27, 2024, AT 2:30 P.M. (EST) ELECTRONIC BIDS WILL NOT BE ACCEPTED (including email, fax, etc.).**
2. All Bids are to be completed upon this document, and must be filled in, in ink or typewritten and fully completed.
3. Material specifications are required on substitutions with **SEALED BIDS** submitted.
4. The Authority reserves the right to accept or reject any or all bids and to waive any informality so designated by the Code of Virginia in bids received.
5. No bids may be withdrawn for a period of 30 days after opening of bids. Unless, in accordance with Title 11, Chapter 7, Section 11-54, Code of Virginia, the bidder gives notice in writing of his claim of right to withdraw his bid within two business days after the conclusion of the bid opening procedure, in the event of unintentional arithmetic or similar mistake made directly in the compilation of the bid.

FIRE HYDRANT MAINTENANCE AND PAINTING REQUIREMENTS

1. A four-foot diameter area shall be trimmed around each hydrant. This includes grass and any other type of vegetative growth.
2. The fire hydrants shall be tested for proper operation.
3. The fire hydrants shall be serviced according to the manufacturer's recommendation. Approved lubricant shall be added as required.
4. The existing paint coating on the fire hydrants shall be cleaned of all foreign material. The existing coating should be dulled by abrading the surface. The contractor shall be responsible for maintaining control of the spent media, and for any damage that may be caused to any property.
5. Only high-grade premium oil-based SAFETY RED paint shall be allowed. Sherwin Williams Urethane Alkyd Enamel, B54-150.
6. Hydrants with offset "steamer nozzles" have a non-standard thread, the steamer nozzles on these hydrants shall be painted EXTRA WHITE. Sherwin Williams Urethane Alkyd Enamel, B54-150.
7. Each hydrant shall be inspected by CCUSA Staff before it is accepted as complete.
8. If the final coat is not smooth, the Contractor shall be instructed to remove the entire coating down to bare metal and start over!
9. The bid price shall be per hydrant; we strongly recommend that the contractors visit the hydrants to determine what shall be required.
10. This bid is for 1250 Fire Hydrants.
11. Please include qualifications and estimated completion time.
12. A background security check will be required for all individuals designated for this project.

In compliance with the above invitation for pricing and subject to all the conditions herein, the undersigned offers to furnish the services and materials as herein described.

BID PRICE PER HYDRANT _____ X 1250 = _____ TOTAL LUMP SUM

SPECIAL CONDITIONS and REQUIREMENTS

1. CCUSA reserves the right to cancel the contract at any time, if deemed to be in the best interest of CCUSA.

2. The vendor shall procure, maintain, and provide proof of insurance coverages for injuries to persons or damages to property which may arise from or in connection with the work performed on behalf of CCUSA by the vendor, his agents, representatives, employees, or subcontractors. The vendor for the duration of the contract period shall maintain such coverages includes:

a. Broad Form Commercial — General Liability: Occurrence basis: \$2,000,000

b. Automobile Liability: All Autos - \$2,000,000

c. Workers Compensation: Statutory Amount

Please state your ability to comply with these requirements.

YES

NO

In compliance with the above invitation for bid and subject to all the conditions herein, the undersigned offers to furnish fire hydrant painting and maintenance.
Quotation By:
Address:
Telephone Number:
E-Mail:
Dated:
Signature:
Title: